STATE OF MISSOURI

DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION

MISSOURI STATE OPERATING PERMIT

In compliance with the Missouri Clean Water Law, Chapter 644 R.S. Mo. as amended, hereinafter the Law, and the Federal Water Pollution Control Act (Public Law 92-500, 92nd Congress) as amended.

Permit No.	MO-0126098
Owner: Address:	Carriage Oaks Not for Profit Water and Sewer Corporation 209 Falling Leaf Court, Branson West, MO 65737
Continuing Authority: Address:	Same as above Same as above
Facility Name: Facility Address:	Carriage Oaks Estates Wastewater Treatment Facility 209 Falling Leaf Court, Branson West, MO 65737
Legal Description: UTM Coordinates:	NE¼, NE¼, Sec. 12, T22N, R23W, Stone County X = 467064, Y= 4053895
Receiving Stream: First Classified Stream and ID: USGS Basin & Sub-watershed No.:	Unnamed tributary to Table Rock Lake (U) Table Rock Lake (L2) (7313) 303(d) List (11010001-1404)

is authorized to discharge from the facility described herein, in accordance with the effluent limitations and monitoring requirements as set forth herein:

FACILITY DESCRIPTION

<u>Outfall #001</u> – NON-POTW – Subdivision – SIC # 8641
No Certified Operator Required.
Recirculating sand filter / chemical addition to facilitate phosphorus removal / flocculation tank / tertiary filtration / chlorination / dechlorination / sludge removal by contract hauler
Design population equivalent is 104 PE.
Design flow is 7,800 gallons per day.
Actual flow is 1,700 gallons per day.
Design sludge production is 1.04 dry tons/year.

This permit authorizes only wastewater discharges under the Missouri Clean Water Law and the National Pollutant Discharge Elimination System; it does not apply to other regulated areas. This permit may be appealed in accordance with Section 644.051.6 of the Law.

<u>August 1, 2013</u> Effective Date	<u>April 1, 2017</u> Modification Date

Steven Feeler
Steven Feeler, Acting Director, Division of Environmental Quality

David J. Lamb
David J. Lamb, Acting Director, Water Protection Program

<u>July 31, 2018</u>
Expiration Date

RESPONDENT'S EXHIBIT 1