

-
- 1 DUE TO PHASING AND SAFETY REQUIREMENTS, NEW CABLE CAN NOT BE INSTALLED IN EXISTING CONCRETE TUNNEL.
- 2 CABLE IN THE TUNNEL WILL BE REPLACED PER THE PROJECT SCOPE.
- 3 DOE CABLE INSIDE THE MAIN BUILDING IS NEW. CABLE FROM SWITCHGEAR WILL BE SPliced TO THE INSIDE CABLE IN AREA INDICATED.
- 4 COLUMN LINES (GRID) AT 40' CENTERS.
- EXISTING SECONDARY CABLE RUNS TO BE REPLACED
25,26,27,28,29,32,46,47,48,49,
53,54,33,34,35,36,55,56,57,&58
- CONCRETE ENCASED UNDERGROUND CONDUITS
33,34,35,36,
55,56,57,&58
- CONCRETE CABLE TUNNEL
- NEW CABLE SPLICES THIS AREA
- 15KV, CONC. ENCASED UNDERGROUND MAIN FEEDER CABLES
- 161KVA OUTDOOR SUBSTATION CO 1319
- FAA BLDG.
- GSA DOE
- CONCRETE CABLE TUNNEL
- WEST BOILER HOUSE
- MAIN SWITCH GEAR PO 2018
- SUB 25
- 31&51
- 30A
30B
30C
45
32
- MH1
- MH2
- MH3
- MH4
- MH5
- MH6
- MH7
- GSA
- SUB 30
- DOE
- SPECIAL DEMOLITION AREA
- 36,&58
- WASTE DISPOSAL BLDG 75
- POLYMER BLDG 15
- PRETREAT BLDG
- KINEMATIC LAB BLDG 16
- TO SANITARY SEWER LIFT STATION
- TO IRS
- BLDG 74
- 33,34,35,
55,56,&57
- F.P. STG. TANK BLDG. 89
- SPEC PROC BLDG. 96
- PLATING BUILDING
- EAST BOILER HOUSE
- M.S.B.
- MAIN BUILDING
- 92
- Exhibit