



Document name	WECC Board of Directors Request Regarding Performance Category Upgrade Request
Category	<input type="checkbox"/> Regional reliability standard <input type="checkbox"/> Regional criteria <input type="checkbox"/> Policy <input type="checkbox"/> Guideline <input checked="" type="checkbox"/> Report or other <input type="checkbox"/> Charter
Document date	
Adopted/approved by	
Date adopted/approved	
Custodian (entity responsible for maintenance and upkeep)	
Stored/filed	Physical location: Web URL:
Previous name/number	(if any)
Status	<input type="checkbox"/> in effect <input type="checkbox"/> usable, minor formatting/editing required <input type="checkbox"/> modification needed <input type="checkbox"/> superseded by _____ <input type="checkbox"/> other _____ <input type="checkbox"/> obsolete/archived)

Attachment 2

Performance Level Adjustment Record (PLAR)

Comments

Facility Outage	Specified Category	Adjusted Category	>300 Yr MTBF	Cascading Allowed	Date BOD Approved	
Hassayampa-Pinal West and Hassayampa-Jojoba 500-kV lines	C	D	No	No	6/27/2012	
Hassayampa-Pinal West and Jojoba-Kyrene 500-kV line	C	D	No	No	6/27/2012	
Hassayampa-North Gila existing and 2nd Future 500-kV lines	C	D	No	No	12/8/2010	
Palo Verde-Westwing Line 2 and Palo Verde-Rudd 500-kV lines	C	D	Yes	No	12/8/2010	
Imperial Valley-Miguel and Imperial Valley-Central 500-kV lines	C	D	No	No	4/16/2008	
Both Palo Verde-Westwing 500-kV lines	C	D	Yes	No	Aug-03	
Raver-Echo Lake and Shultz-Echo Lake 500-kV lines	C	D	Yes	Yes	Aug-02	
From Prior Exceptions List						
Laramie River-Ault and Laramie River-Beaver Creek 345-kV lines	D	D	NA		Aug-01	Separate rights-of-way, Separate substation bays
Navajo-McCullough and Navajo-Moenkopi 500-kV lines	D	D	NA		Aug-01	Separate rights-of-way, Separate substation bays
Navajo-Westwing and Navajo-Moenkopi 500-kV lines	C	D	No		Aug-01	Same right-of-way, no 2 line outages have occurred
Palo Verde-Devers and Palo Verde North Gila 500-kV lines	D	D	NA		Aug-01	Separate rights-of-way, Separate substation bays
Lugo-Eldorado and Lugo-Mohave 500-kV lines	C	D	No		Aug-01	Same right-of-way for only 33% of length
Navajo-McCullough and Moenkopi-Eldorado 500-kV lines	D	D	NA		Aug-01	Separate rights-of-way, Separate substations

(other exceptions were RAS failures - omitted because handled differently)

NA - No Probabilistic-based Reliability Criteria adjustment is needed because the facilities are on different rights-of-way with different terminations

Updated June 29, 2012