



Economic, Reliability, & Resiliency Benefits of Interregional Transmission Capacity

GE ENERGY CONSULTING

Case study focusing on the Eastern United States in 2035

October 2022


Project contact:

Sheila Tandon Manz, PhD
Technical Director, GE Energy Consulting
Sheila.Manz@ge.com



Economic, Reliability, and Resiliency Benefits of Interregional Transmission Capacity

Case Study Focusing on the
Eastern United States in 2035



geenergyconsulting.com

GE Energy Consulting study for the Natural Resources Defense Council (NRDC).

GE Energy Consulting (study team)

- **Project lead:** Sheila Tandon Manz, Ph.D., Technical Director
- Andrew Bachert, Principal
- Amin Mahdih Najafabadi, Principal
- Jason MacDowell, Technical Director
- Gene Hinkle, Managing Director

Technical Review Committee

- Debbie Lew, ESIG
- Kevin Porter, Exeter Associates
- Rob Gramlich, Grid Strategies
- Jay Caspary, Grid Strategies
- Ric O'Connell, GridLab

Highlights: Greater interregional transmission helps keep the lights on while providing ratepayer savings



GE simulated electric generation across US Eastern Interconnection for a number of weather conditions in 2035-2040 to quantify the benefits of greater interregional transmission for:

- 1) **Resiliency**
- 2) **Affordability**
- 3) **Stability**

- **HEAT WAVE, AUGUST 2035: Greater transmission prevented ~740,000 customers losing power** across New York City and Washington, DC saving \$875M
- **POLAR VORTEX, FEBRUARY 2035: Greater transmission prevented ~2 million customers losing power** across Boston, New York City, Baltimore and Washington, DC saving \$1B
- **NORMAL WEATHER, 2035: Greater transmission saved \$3B/year in 2035 increasing to \$4B in 2040** via greater access to lower cost generation
- Greater transmission **lowered capacity and ancillary service requirements, saving \$2B** in 2035
- Example cost benefit analysis shows **\$12B in net benefits** from 87GW of incremental interregional transmission

Grid stability is also increasingly a risk during extreme weather events. Alternate interregional transmission technologies (e.g. DC vs AC connections) should be considered to maintain stability especially with high inverter-based resource penetrations.

Interregional transmission expansion can have multiple benefits



- 1. RESILIENCY:** The lights can stay on in the face of greater uncertainty/extreme weather

- 2. AFFORDABILITY:** Customers experience lower energy costs via access to lower cost generation

- 3. STABILITY:** The lights can stay on as grid technologies diversify

—
How can FERC determine a minimum interregional transmission requirement?

How can FERC define a minimum interregional transmission requirement?



Potential customer benefits of interregional transmission

Memo to


American Council on Renewable Energy (ACORE)

Submitted by: General Electric International, Inc.
Revision No. Final
29 November 2021

- Industry has considered several possible metrics:
 - Flat percentage of load or generation
 - Single largest contingency
- GE published a paper for ACORE suggesting a methodology based on *interregional power flow needs & benefits*
- Current study work focused on simulations illustrating methodology implementation

https://acore.org/wp-content/uploads/2021/12/02-GEEnergyConsulting_ACORE_InterregionalTransmissionMemo_211129.pdf

GE proposed methodology: Simulate system w/constrained & unconstrained transmission to compare benefits & suggest requirement



GE MAPS* MODEL

- ✓ Interconnect-wide: Imports/exports
- ✓ Nodal: transmission-dependent
- ✓ Hourly and forward-looking
- ✓ Supercomputer-enabled

GE simulated the Eastern Interconnection (EI) in GE MAPS*

1. Under two **transmission conditions**

- Constrained** transmission flows
- Unconstrained** transmission flows
(transmission w/ Canada remains constrained)

Assumes *inter-regional* needs coordinated w/ *intra-regional*


2. For three different **weather conditions**:

- Heat** wave
 - Polar** vortex
 - Normal** weather: Test affordability benefits
- } Test resiliency benefits

GE also performed an analysis on subset of EI to assess potential stability qualifications

Ref: ABB Hitachi * Trademark of General Electric

GE simulated two extreme weather scenarios



Two extreme weather events were simulated:

- 1) **Summer Heat Wave:** Load 30% higher due to extreme heat
- 2) **Winter Polar Vortex:**
 - Load 40% higher due to extreme cold
 - ~15% generation outages due to fuel constraint
 - Gas prices spike to \$40/MMBTU due to shortages

Eastern seaboard represents ~35% of total peak load for the Eastern Interconnect.

Ref: ABB Hitachi


Heat wave 2035: Unconstraining transmission eliminates load losses

Demand increased 30% due to heat




2035 CONSTRAINED TRANSMISSION

Constrained interregional power flows led to load losses



2035 UNCONSTRAINED TRANSMISSION

Higher avg. interregional power flows enabled load to be served



Ref: ABB Hitachi

Heat wave 2035: Up to 600,000 (20%) NYC customers lose power

Increased imports avoided power losses




2035 CONSTRAINED TRANSMISSION

Constrained power flows led to load losses

2035 UNCONSTRAINED TRANSMISSION

Higher imports allow load to be served





1 | Resilience

Average power flows can inform a *heat wave* interregional transmission requirement



Average power flow differences can be used to inform an interregional transmission requirement

Importing region can be assigned the requirement




Polar vortex 2035: Unconstraining transmission eliminates load losses

Demand increases 40%, 15% generation outages & gas price spikes to \$40/MMBTU due to cold



2035 CONSTRAINED TRANSMISSION


Constrained interregional power flows led to local outages



Ref: ABB Hitachi

2035 UNCONSTRAINED TRANSMISSION

Higher avg interregional power flows alleviated supply constraints



*Constraints w/ Canada not relaxed

Polar vortex 2035: Up to 600,000 (20%) NYC customers lose power

Increased imports avoided power losses




2035 CONSTRAINED TRANSMISSION

Constrained power flows led to load losses

2035 UNCONSTRAINED TRANSMISSION


Higher imports allow load to be served

2035 hourly generation by fuel type (MW)



- Up to 600,000 customers lose power (20% max load shed)
- 18 hrs. of load losses
- 22% load served by imports

STORAGE
IMPORTS
OFFSHORE
GAS



- No customers lose power
- 27% load served by imports



1 | Resilience

Average power flows can inform a polar vortex interregional transmission requirement




Average power flow differences can be used to inform an interregional transmission requirement

Importing region can be assigned the requirement




Requirement as % of peak	PJM	SERCN	FRCC	SERCSE	SERCE	MISO	ISONE	SPP	NYISO
	9%	32%	17%	20%	17%	5%	5%	0%	0%

Summarizing the interregional transmission requirement: Consider average power flows across the weather scenarios





Unconstraining transmission lowers total capacity requirement saving ~\$2B in 2035





Unconstraining transmission lowers spinning reserve needs saving ~\$50M/year in 2035

CONSTRAINED TRANSMISSION

605GW



UNCONSTRAINED TRANSMISSION

601GW



UNCONSTRAINING TRANSMISSION UNLOCKS EXCESS SPINNING RESERVES

$\Delta = 4\text{GW}$ lower spinning reserve requirement
 ~\$50M/yr value @\$1.51/MWH PJM average price

Total required spinning reserves lower due to sharing of reserves across larger footprint
Additional economic benefits likely given sharing of other reliability services

2 | Affordability


\$3B in production cost savings w/expanded interregional power flows

Could unconstrained power flows inform a minimum interregional transmission requirement?




2035 Constrained transmission

Average interregional power flows



2035 Unconstrained transmission

Higher average interregional power flows



Ref: ABB Hitachi



2 | Affordability

Interregional transmission enables ratepayer savings via access to lower cost generation



Transmission allows high-cost regions like Florida and New England to access lower cost generation

Using lower cost generation saves ratepayers \$4B/year by 2040



Ref: GE Energy Consulting non-proprietary database



2 | Affordability

Average power flows can inform an *affordability* interregional transmission requirement



Average power flow differences can be used to inform an interregional transmission requirement

\$48B estimated transmission cost ... importing region can absorb costs




Requirement as % of peak	FRCC	SERCSE	SERCN	SERCE	PJM	MISO	SPP	ISONE	NYISO
	25%	30%	19%	14%	2%	2%	3%	6%	0%

Total interregional transmission requirement will have two components




Total interregional transmission requirement = Resiliency component + Affordability component

Affordability and resilience components by interregional interface



Components by importing region




Requirement as % peak	PJM	SERCN	SERCSE	FRCC	SERCSE	MISO	SPP	ISONE	NYISO
Requirement as % peak	12%	40%	30%	25%	24%	4%	2%	6%	0%



Total interregional transmission pays for itself in total benefits

\$71B estimated transmission cost ... importing region can absorb costs

\$83B estimated total benefits ... likely higher given additional ancillary savings



Cost assumptions

- 500MW/tie line
- 100 mi @\$3M/mi in 2035
- NYISO interfaces: 50 mi @\$30M/mi

Benefit assumptions

- Capacity build over 4 years
- \$25,000/MWH loss of load cost
- Extreme events every 10 years

Should interregional transmission requirements consider stability?



Interregional transmission requirements may need to go beyond AC lines to strengthen grid

As resources diversify, grid stability is increasingly a factor in resilience

The interregional grid can have adequate generation & transmission but still be unstable

- Stable **frequency** & **voltage** (e.g. 60Hz & 230kV)
- Stable during **normal** conditions
- Stable after a **disturbance** (i.e. generator trips, tree hits a line ... often in storms, wildfires + cascading)

An interregional AC transmission requirement may be insufficient for a stable grid

Potential screening methodology

Step 1: **Is grid stable** w/ incremental interregional AC transmission requirement?

- | | |
|---------------|---|
| PASS
/FAIL | <input type="checkbox"/> Weak grid? Short circuit current ratio acceptable (e.g. SCR>3)? |
| | <input type="checkbox"/> Stable frequency? Synchronous unit headroom acceptable? |
| | <input type="checkbox"/> Small signal instabilities? Unwanted resonances? |

If all pass: **Great! The AC requirement is sufficient**

If any fail: **Requirement to include a qualifier to reinforce until all pass**

Interregional transmission may need to consider beyond AC lines for extreme weather stability


3 | Stability

Example: Even with significant AC interregional reinforcement, Eastern seaboard grid remains weak



2035 CONSTRAINED TRANSMISSION

Weak grid onshore and offshore



2035 EXPANDED INTERREGIONAL TRANSMISSION

Onshore grid strengthened ... offshore grid still weak



- ★ Assumed offshore POIs
- ➡ Assumed incremental interregional transmission (GW)



Reinforcements beyond AC lines may be needed to strengthen grid

- DC vs. AC connections
- Synchronous condensers
- Grid forming controls

Ref: ABB Hitachi

Ongoing GE work



Including resiliency economic benefit via constrained vs. unconstrained reserve margins

CONCLUSIONS THUS FAR

~\$3-4B/year production cost savings enabled by unconstraining interregional transmission under normal weather conditions

Load shedding avoided during simulated heat wave and polar vortex events via unconstrained transmission

GE proposed a methodology for quantifying incremental interregional transmission requirement via increase in average power flows enabled by unconstraining transmission across weather events

FERC can consider this methodology to enable the definition of an incremental transmission requirement between each pool in its jurisdiction. Cost allocation could follow importing region.




Building a world that works



Assumptions


Renewables and gas grow ... coal declines




Load growth ~1%/year across pools ... steeper growth 2040+



Energy demand by pool and year (GWH)



Peak load by pool and year (MW)



GE Energy Consulting load assumptions come directly from RTO-issued forecasts. Most recent forecasts included higher load assumptions given expected electrification

Henry Hub gas price assumption: long term prices rising

GE then calculates delivery charges to electric generators across the US

