## **Park Estates**

**Park Estates** 

End of NE 170th Street West of Highway 33, Kearney, MO 64060 Owner- Central Rivers Wastewater Utility Inc., P. O. Box 528, Kearney, Mo 64060

> MO-0126004 Effective date as of 03-05-2010 Must be revaluated 03-04-2015

Outfall #001--Subdivision-SIC # 4592

Septic Tank Effluent Pump (STEP) System/ recirculating sand filter/ sludge disposal by contract hauler

Receiving stream - Unamed tributary to Clear Creek

Design population equivalent is 196

Design flow 20,000 gallons per day

Actual flow is ??? gallons per day

Design sludge production is 1.4 dry tons/year

Actual sludge production is ???

Any documentation, illustration, verification, or questions needing to be completed in the flowing report can be reviewed and produced by:

WET RPM Robert Betts 660-351-1236

betts1213@gmail.com

Any documentation, illustration, verification, or questions needing to be completed in the flowing report can be reviewed and produced by:

WET RPM Robert Betts 660-351-1236

betts1213@gmail.com

Effluent TSS	Effluent BOD	Effluent Fecal	Effluent Ammonia	Effluent DO	Effluent TEMP must be done on site	Effluent Flow  Effluent PH must be done on site	DAILY Influent or
,							Which in BI-WEEKLY
							which includes but VEEKLY WEEKLY
							Includes but may not be limited to the WEEKLY BI-MONTHLY QUARTER
24 hr. modified composite within the first week of each quarter	24 hr. modified composite within the first week of each quarter	Grab within the first week of each month from April 1 thru Oct. 31	within the first week of each quarter	(WET RPM recommends)	Grab within the first week of each quarter	24 hr. estimate Grab within the first week of each quarter	QUARTERLY SIMI-4
5	_						SIMI-ANNUAL
							ANNUALLY
			,				PERMIT CYCLE

								d
			than 6"					Ground
			maintain fence					-
			vegetation and		and the second			
			Remove					
	Betore January 28							Sludge report
			vegetation					Sand filter
			drain Remove					
			but					
			Flush distribution					
	sludge		filter		readings			tanks
	Remove		screens Clean	A) to make	pumps hour			Recirulating
			Clean pump					-
	sludge	recommends)	each tank					Septic Tanks
	Remove	(WET RPM	Clean filter in					
		Sludge judge		-	i de			
			following month					DMRs
		-200	Before 28 of the	Andre				
			recommends)					Ammonia
WWW. 1900.			RPM					Influent
			quarter (WET					
			week of each					
			within the first					
			Grab					
			recommends)					on site
			(WET RPM					
	a - 1744		Grab					Influent Temp
			recommends)					on site
			(WET RPM					2
			Grab					Influent PH
permit cycle	ANNUALLY	SIMI-ANNUAL	QUARTERLY	BI-MONTHLY	WEEKLY	BI-WEEKLY	DAILY	
T	VIIVIIIII			1			•	

comments	review and	Draft permit	application	Permit	renewal	Permit	budget	Rate study and	Compliance	Schedule of												SSO			meter	PH and DO	
									7/28/2013	to be met by	Final effluents need											hours online	occurrence within 24	Report any			DAILY
									be taken	must	12 Fecal	minimum of	2011	2010 to Mar	From Mar			policio (n)									BI-WEEKLY
									DNR	submitted to	must be	spesifications	and	report/plans	engineering	copy of	permit and a	construction	for	an application	Mar 5,2012-						WEEKLY
									DNR	submitted to	must be	modifications	engineering	information,	additional	request for	of DNR's	Within 15 days									BI-MONTHLY
				-		<del></del>			constructed	must be	improvements	permit	construction	of issuance of the on construction	Within six months										and PH meter	QA/QC both DO	MONTHLY
									form to DNR	completed	work	statement of	must submit a	on construction	months of completion	Within 15 days											SIMI-ANNUAL
							update	Review and																			ANNUALLY
4/4/2015			9/4/2014		3/4/2015																						permit cycle

Facility operators under this permit does not requires any licensed operator but a licensed D operator is recommended. Waste water treatment equipment and facility must be effectively operated and maintain by a competent person.

24 hr. Modified Composite made up from a minimum of four grab samples collected within 24 hrs, with a minimum of 2 hours between each grab sample.

Permitee is subject to standard conditions part I, III

Any discharge within the reporting period must be reported

If no discharge DMRs still need to be reported

Operator should notify permitee when sample are taken.

Permitee must follow all 10 CSR 20 regulations.

Effluent sample must be taken at outfall

Test procedures must follow standards methods

When taking samples the date, exact place, time, and individual taken sample must be recorded

When analyses are being preformed the date, individual, analytical techniques and results must be reported on DMRs.

More than required monitoring can be preformed but must be reported on DMRs

Any facility expansion or process modification requires a construction permit from DNR

Any noncompliance which may endanger health or environment must be orally provided within 24 hour to DNR All other noncompliance must be reported in writing to DNR within five days A written report must follow up within five days

When any substance is removed from the facility such as sludge, grit or screening the permitee must record and maintain the date, time, volume and disposal site

Any bypass or SSO that occurs in the facility must be reported to DNR online or by phone within 24 hr. if by phone A written report must follow up within five days.

All records must be retained at the facility for at least three years. All records must be available upon DNR request.

Civil and criminal liability fall on the permitee

Monitor any effluent introduced by major contributing industry

Issue pretreatment permit to any major contributing industry and give notice to DNR

Permitee is responsible for final disposal unless contract hauler has separate permit for sludge disposal, or contract hauler transport sludge to another permitted facility.

Permitee must require and maintain documentation on contract hauler of disposal methods, permits and total solids contents.

All outfalls must be clearly marked in the field as outfall 001

Discharges will not cause violation of water quality standards rules of 10 CRS 20

Facility must have at least one sign on each side of facility.

Facility must provide O&M manuals to the operator.

All weather access roads to facility

The discharge from the system must be conveyed to the receiving stream by close pipe or open rip-rapped channel and maintained for easy sampling access.

Spare parts need to be on hand for any equipment that require routine maintenance and repairs.

All collection systems components need to have a inspection and repair program in place

A rate study and budget needs to be completed and updated annually for the facility to be able to operate, maintain, and upgrade facility keeping the facility in compliance.