

K

# Miller/Lindsay Laboratory

P.O. Box 282, 1037 Osage Beach Road, Osage Beach, MO 65065

Phone 573-348-9799 Fax 573-348-2894

e-mail rocky@millerlindsay.com

FILED

JAN 16 2004

Missouri Public  
Service Commission

Laboratory Certification # 00940

Analysis Performed By: Mark Henson

Analysis Date: 12/15/03

To: John Kelly

Sample Identification: Lower Bathroom, 1091B Marina Circle, Osage Beach

Date and Time of Sample Collection: 12/15/03

Sample Collected By: John Kelly

## RESULTS:

The sample referenced above was positive for Total Coliform and negative for E coli. The sample does not meet the microbiological requirements for public drinking water from Department of Natural Resources or Department of Health. The source should be disinfected and retested.

ADDRESS- John M. Kelley  
1091 B Marina Cir  
Osage Beach, MO 65065

Old water also smells like raw sewage when taking a shower or starting washing machine. It also turns orange and yellow and brown. COPY

Camden  
Public Hearing Camden, MO. K  
Date 1-13-04 Case No. ST-2003-0562  
Reporter KF