

FORM NO. 13

P.S.C.MO.No. 6

Original
~~Revised~~
Original
Revised

SHEET No. R7.0

Cancelling P.S.C.MO.No.

SHEET No.

ST. LOUIS COUNTY WATER COMPANY

For

ST. LOUIS COUNTY, MISSOURI

Name of Issuing Corporation

Community, Town or City

METER TESTING/ADJUSTMENTS FOR METER ERROR
(ADJUSTMENT TO BILL FOR METER ERROR)

RULE 7.0 Customers shall accept the meter installed by the Company as the standard of measurement for water service. If the meter, when inspected and tested using the Company's intermediate and maximum flow rate testing procedures, shall be found to be more than five percent (5%) defective or incorrect to the prejudice of the customer or the Company, the Company, as a basis for adjusting the billing to the customer, will determine the quantity of water used, either by a test of the meter, by the amount of water used during a corresponding period the preceding year, or by an estimate based on the average amount of water used during the preceding twelve months proportioned to the period during which the meter is shown to have become defective or inaccurate, at the Company's option. If the Company is unable to read a customer's meter at a regular reading time, the Company shall estimate the amount of water used for billing purposes as described in Rule 5.0, which billing shall be adjusted, if necessary, at the time a meter reading is obtained.

+

+

FILED
February 22, 2008
Data Center
Missouri Public
Service Commission

MAWC Exhibit No. 3
Case No(s) WC-2008-0106
Date 1-31-08 Rptr RF

*Indicates new rate or text
+Indicates change

DATE OF ISSUE

SEP 24 1984

DATE EFFECTIVE

OCT 24 1984

month day year

month day year

ISSUED BY

H. E. Molman, V.P., Comp.; 535 N. New Ballas Rd., St. Louis, MO 63141

name of officer

title

address

MAWC Exhibit 4.7