



Kennett Board Of Public Works

P.O. BOX 40 • KENNETT, MISSOURI 63857-0040 • (573) 888-5366 • FAX (573) 888-3312

Oct. 19, 2015

RECEIVED²

OCT 23 2015

*Records
Public Service Commission*

Mr. Morris Woodruff
Secretary
Missouri Public Service Commission
200 Madison Street, Suite 100
P.O. Box 360
Jefferson City, MO 65102

Mr. Woodruff,

Enclosed is our annual report for the Three Rivers Community College (formerly Emerson Electric) yard line.

We are providing this report pursuant to Missouri Public Service Commission Case No. GE-2003-0503.

Sincerely,

George Anderson
Gas Department Superintendent
Kennett Board of Public Works
Kennett, MO 63857

cc: Mr. Bob Leonberger
Missouri Public Service Commission
P.O. Box 360
Jefferson City MO, 65102

**Annual Report for Three Rivers Community College Yard Line
(Formerly Emerson Electric Yard Line)**

Date: Oct. 19, 2015

Yard Line leak survey results on 6" line: Leaks Found: Yes ☐ No ☒

If leaks found, what was done: _____

Cathodic protection readings on 6" line:

Test Point #1: -1.44v Test Point #2: -1.45v Test Point #3: -1.51v Test Point #4: -1.46v

Work performed by: Bill Heinen

(Pursuant to Missouri Public Service Commission Case No. GE-2003-0503)