

Order: TGPR 0000499971 1Y Verify Building Heater Operation

1Y Verify Building Heater Operation
 WOs created to fix some of the broken heaters.
 ST building: 100000511101
 Shop heaters: 100000511102
 As of 10/13/2025 these heaters still need to be checked:

Gas Turbine- NE not working
 Gas Turbine Generator-South fan not running
 Gas Turbine Hydraulic oil- not working

Sys.Status: CLSD JBFI MANC NMAT PRC SETC RCOM

HeaderData Operations Components Costs Partner Objects Additional Data Location Planning Control Enhancement

Person responsible

PlannerGrp: 020 /: 5165 LU Empire Thermal Notifctn: 100000905697 63

Mn.wk.ctr: THERMAL /: 5165 Empire Thermal Riverton Costs: 0.00 USD

Person respons.: PMActType: 615 Inspection

SystCond.: Address:

Dates

Bsc start: 09/21/2025 00:00 Priority: 3 30 Days

Basic fin.: 10/21/2025 00:00 Revision:

Reference object

Func. Loc.: GN-T-RIVR Riverton Thermal Plant

Equipment: