

Order: TGPR 100000518132 Permanent heaters in new warehouse

1 60amp 3 phase 480v breaker  
 conduit and fittings  
 #6 awg copper wire for feed  
 ds 10/29/25

New heaters installed and operational in NW and SW corners of New WH  
 SW Heater is Cir 8/10/12 480V Panel  
 NW Heater is Cir 2/4/6 480V Panel  
 DS/FT 12/10/25 on/off thermostat control has been added below each  
 heater ds 1/19/26

Sys.Status: CLSD GMPS JBFI NMAT PRC SETC RCOM

HeaderData Operations Components Costs Partner Objects Additional Data Location Planning Control Enhancement

Person responsible

PlannerGrp: 020 /: 5165 LU Empire Thermal  
 Mh.wk.ct: THERMAL /: 5165 Empire Thermal Riverton  
 Person respons.:  
 Notifctn: 100000930307  
 Costs: 0.00 USD  
 PMActType: 615 Inspection  
 SystCond.:  
 Address:

Dates

Bsc start: 10/29/2025 09:14 Priority: 3 30 Days  
 Basic fin.: 12/15/2025 09:14 Revision:

Reference object

Func. Loc.: GN-T-RIVR-BOPL-STRU Structures & Improvements  
 Equipment: 21027154 Storage Building 150'x80'