



Select Text Symbol Definition Services for Object More

F...	L...	Row Text	R..
	+....1....+....2....+....3....+....4....+....5....+....6....+.....	
*		This work order is a result of the NERC building heater check pm.	
*		During inspection the following heaters were found not working at all...	
		not working:	
*		12BSA-UH-2025- Fan works but no heat.	
*		12BSA-UH-1001- Not working.	
*		12BSA-UH-1007- Not working.	
*		12BSA-UH-1009- Not working.	
*		Info for work order provided by R.Lewis. 10/12/2025	
*			
*		The following work was completed on 10/18/2025 ROL. All heaters are	
*		operational as of 10/18/2025.	
*		Do not close work order until parts have been charged. Thanks.	
*			
*		2025-Adjusted thermostat and heater started heating	
*			
*		1009-reset manual cutout on back of heater and returned to service	
*			
*		1007-Found fan to be nearly seized up due to bad bearings. replaced w...	
		new heater from stock and will replace fan in the heater that was	
		removed from wall and put in warehouse for later use.	
*		fan has been replaced, heater is tested and is on the shelf in the new	
*		warehouse. 11/16/2025 ROL	
*			
*		1001-replaced bad capacitor. returned to service	
*		Blake charged (1) 108378 motor. BJ 11/19/2025	